



Certificate of Compliance

This certificate is issued for the following:

Pipe Hanger Components for Automatic Sprinkler Systems

Tembo Global, Pipe Clamps

<i>Product Designation</i>	<i>Hanger Rod Size, in. (mm)</i>	<i>Component Description</i>	<i>For Nominal Pipe Sizes, in.</i>	<i>Remarks</i>
NCR	3/8 (10)	Pipe Hanger with Lining	3/4, 1, 1 1/4, 1 1/2, 2, 2 1/2, 3, 4	-

Prepared for:

Tembo Global Industries Ltd
Plot No. 146/147 MIDC – Turbhe -
TTC, Navi Mumbai,
Maharashtra 400703,
India

Manufactured by:

Tembo Global Industries Ltd
Unit No. 1/B – Badrinath, Ground Floor,
Tungreshwar Industrial Complex
Sativali Village, Vasai (East), Dist.
Thane, Maharashtra 401208,
India

FM Approvals Class: 1951, 1952, 1953 Issue Date December 2016

Approval Identification: 3056409
Superseded by: RR224763

Approval Granted: April 25, 2016
Date Approved: September 2, 2020

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following:

Pipe Hanger Components for Automatic Sprinkler Systems

Sprinkler Hanger Models SH1, SH2, SH3, SH4
C-type Clamp Models BCU, BCT
(see attached listing)

Prepared for:

Tembo Global Industries Ltd
Plot No. 146/147 Turbhe MIDC – TTC
Navi Mumbai, Maharashtra 400705
India

FM Approvals Class: 1951 (December 2016)

Approval Identification: PR456429

Approval Granted: May 13, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group



Certificate of Compliance

Loop Hangers

Model No	Description	Hanger Rod Size, in (mm)	Nominal Pipe Size	
			in	(mm)
SH	Loop Hanger	3/8 (10)	3/4, 1, 1 1/4, 1 1/2, 2, 2 1/2, 3, 4	(20, 25, 32, 40, 50, 65, 80, 100)
SH	Loop Hanger	1/2 (12)	5, 6, 8	(125, 150, 200)
SH2	Loop Hanger	3/8 (10)	3/4, 1, 1 1/4, 1 1/2, 2	(20, 25, 32, 40, 50)
SH3	Loop Hanger	3/8 (10)	2 1/2	(65)
SH4	Loop Hanger	1/2 (12)	3, 4, 5, 6	(80, 100, 125, 150)
SH1	Loop Hanger	3/8 (10)	3/4, 1, 1 1/4, 1 1/2, 2	(20, 25, 32, 40, 50)

C-Type Clamps

Model No	Description	Hanger Rod Size, in (mm)	Nominal Pipe Size	
			in	(mm)
BCU	Beam Clamp	3/8 (10)	3/4 through 4	(20 through 100)
BCT	Beam Clamp	1/2 (12)	5, 6, 8	(125, 150, 200)



Member of the FM Global Group